



Certificate of Compliance

Certificate: 2652246 (112384_0_000)

Master Contract: 187265

Project: 70051389

Date Issued: 2016-01-11

Issued to: Apollo Valves (Conbraco Industries, Inc.)
1418 S Pearl St
Pageland, South Carolina 29728
USA

Attention: Stephen Vollentine

The products listed below are eligible to bear the CSA Mark shown



Issued by: *James Sekerak*
James Sekerak

PRODUCTS

CLASS - C337110 - VALVES (GAS)-Lever Operated Non-Lubricated Shutoff

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

For Use with Natural and Propane Gas

For Use with Natural, Mfd., Mixed, Liquefied Petroleum or Propane Gases and LP Gas-Air Mixtures

Straight Through

Model Number

89-101-01A, Rated Pressure: 125 psi, Inlet Size: ¼”
89-102-01A, Rated Pressure: 125 psi, Inlet Size: 3/8”
89-103-01A, Rated Pressure: 125 psi, Inlet Size: ½”
89-104-01A, Rated Pressure: 125 psi, Inlet Size: ¾”
89-105-01A, Rated Pressure: 125 psi, Inlet Size: 1”
89-106-01, Rated Pressure: 125 psi, Inlet Size: 1-1/4”
89-107-01, Rated Pressure: 125 psi, Inlet Size: 1-1/2”
89-108-01, Rated Pressure: 125 psi, Inlet Size: 2”
89-109-01, Rated Pressure: 125 psi, Inlet Size: 2-1/2”
89-100-01, Rated Pressure: 125 psi, Inlet Size: 3”



Certificate: 2652246
Project: 70051389

Master Contract: 187265
Date Issued: 2016-01-11

489-101-01A, Rated Pressure: 125 psi, Inlet Size: ¼”
489-102-01A, Rated Pressure: 125 psi, Inlet Size: 3/8”
489-103-01A, Rated Pressure: 125 psi, Inlet Size: ½”
489-104-01A, Rated Pressure: 125 psi, Inlet Size: ¾”
489-105-01A, Rated Pressure: 125 psi, Inlet Size: 1”
489-106-01, Rated Pressure: 125 psi, Inlet Size: 1-1/4”
489-107-01, Rated Pressure: 125 psi, Inlet Size: 1-1/2”
489-108-01, Rated Pressure: 125 psi, Inlet Size: 2”
489-109-01, Rated Pressure: 125 psi, Inlet Size: 2-1/2”
489-100-01, Rated Pressure: 125 psi, Inlet Size: 3”

APPLICABLE REQUIREMENTS

CSA/CAN3.16-M88 (R-2014) – Lever Operated Non-Lubricated Gas Shut-Off Valves



Supplement to Certificate of Compliance

Certificate: 2652246 (112384_0_000)

Master Contract: 187265

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70051389	2016-01-11	Addition of valve options for Model Series 89 and addition of Model Series 489.
70025881	2015-03-27	Addition of unidirection ball and handle options
2652246	2013-08-21	Authorize a new Model #89-100 Series, (1/4" to 3") straight through, carbon steel, ball type, lever operated, non-lubricated, manual gas shutoff valve.