



# Certificate of Compliance

**Certificate:** 2652246 (112384\_0\_000)

**Master Contract:** 187265

**Project:** 70051389

**Date Issued:** 2016-01-11

**Issued to:** Apollo Valves (Conbraco Industries, Inc.)  
1418 S Pearl St  
Pageland, South Carolina 29728  
USA  
**Attention:** Stephen Vollentine

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** James Sekerak  
James Sekerak

## **PRODUCTS**

**CLASS - C337110 - VALVES (GAS)-Lever Operated Non-Lubricated Shutoff**

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

**For Use with Natural and Propane Gas**

**For Use with Natural, Mfd., Mixed, Liquefied Petroleum or Propane Gases and LP Gas-Air Mixtures**

**Straight Through**

**Model Number**

89-101-01A, Rated Pressure: 125 psi, Inlet Size: ¼"  
89-102-01A, Rated Pressure: 125 psi, Inlet Size: 3/8"  
89-103-01A, Rated Pressure: 125 psi, Inlet Size: ½"  
89-104-01A, Rated Pressure: 125 psi, Inlet Size: ¾"  
89-105-01A, Rated Pressure: 125 psi, Inlet Size: 1"  
89-106-01, Rated Pressure: 125 psi, Inlet Size: 1-1/4"  
89-107-01, Rated Pressure: 125 psi, Inlet Size: 1-1/2"  
89-108-01, Rated Pressure: 125 psi, Inlet Size: 2"  
89-109-01, Rated Pressure: 125 psi, Inlet Size: 2-1/2"  
89-100-01, Rated Pressure: 125 psi, Inlet Size: 3"



**Certificate:** 2652246  
**Project:** 70051389

**Master Contract:** 187265  
**Date Issued:** 2016-01-11

---

489-101-01A, Rated Pressure: 125 psi, Inlet Size: ¼”  
489-102-01A, Rated Pressure: 125 psi, Inlet Size: 3/8”  
489-103-01A, Rated Pressure: 125 psi, Inlet Size: ½”  
489-104-01A, Rated Pressure: 125 psi, Inlet Size: ¾”  
489-105-01A, Rated Pressure: 125 psi, Inlet Size: 1”  
489-106-01, Rated Pressure: 125 psi, Inlet Size: 1-1/4”  
489-107-01, Rated Pressure: 125 psi, Inlet Size: 1-1/2”  
489-108-01, Rated Pressure: 125 psi, Inlet Size: 2”  
489-109-01, Rated Pressure: 125 psi, Inlet Size: 2-1/2”  
489-100-01, Rated Pressure: 125 psi, Inlet Size: 3”

### **APPLICABLE REQUIREMENTS**

CSA/CAN3.16-M88 (R-2014) – Lever Operated Non-Lubricated Gas Shut-Off Valves



## *Supplement to Certificate of Compliance*

**Certificate:** 2652246 (112384\_0\_000)

**Master Contract:** 187265

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
70051389	2016-01-11	Addition of valve options for Model Series 89 and addition of Model Series 489.
70025881	2015-03-27	Addition of unidirection ball and handle options
2652246	2013-08-21	Authorize a new Model #89-100 Series, (1/4" to 3") straight through, carbon steel, ball type, lever operated, non-lubricated, manual gas shutoff valve.

**MASTER CONTRACT:** 187265  
**REPORT:** 2652246  
**PROJECT:** 70051389

**Date Issued:** January 11, 2016

---

The following options are available to all sizes except where indicated for Model Series 89:

<b>Suffix</b>	<b>Option</b>
-02	Stem Grounded
-04	2.25" Stem Extension
-07	Steel Tee Handle
-08	90° Reversed Stem
-10	SS Lever and Nut
-14	Side Vented Ball (Uni-Directional)
-15	Steel Wheel Handle
-16	Vertical Chain Lever
-18	Plain Yellow Grip
-19	Pad-Locking Devices
-24	Graphite Packing
-27	SS Latch-Lock Handle and SS Nut
-30	Cam-Lock Handle and Grounded
-32	SS Tee Handle And Nut
-35	PTFE Trim
-39	SS Hi-Rise Locking Wheel Handle, SS Nut
-40	Cyl-Loc and Grounded
-45	Less Lever And Nut
-46	SS Lock Closed Only
-47	SS Latch-Lock Oval Handle
-48	SS Oval Handle (No Latch) & Nut
-49	No Lubrication. Assembled Dry.
-50	2.25" Locking Stem Extension
-56	Multifill Seats & Packing
-58	Chain Lever - Horizontal
-60	Grounded Ball And Stem
-64	250# Steam Trim
-67	Cleaned for Industrial Gases